


Replacement for Synchronous-Wired 58th Minute Motor Movement

FEATURES

- Complete with correction coil
- Set hands at 4:58 when replacing



DESCRIPTION

This corrective movement performs a 12 hour correction twice daily with a series of correction pulses from the system master clock starting at 5:05:00. Hourly correction is performed with a 55 second correction pulse sent from the system master clock at HH:58:05.

ORDERING INFORMATION

Part #	Description
N1193	120vac/120vac
N1195	24vac/24vac

SPECIFICATIONS

Operating Voltage

120vac	60 Hz	motor = .057 amps	Coil = .020 amps
24vac	60 Hz	motor = .230 amps	Coil = .221 amps

At American Time, we continually strive to improve our products to meet our customers' needs and to provide the best possible value. The above specifications are believed to be correct, are subject to change without notice and may otherwise vary from the above. Please call if you need verification of any specifications or the suitability of a particular product for a particular application. © American Time